



NORTH CANTON BUILDING DEPARTMENT
RESIDENTIAL ROOFING INSTALLATION AGREEMENT

I, Contractor/Installer _____ agree to complete the roof installation at _____, in accordance with the Current Residential Code of Ohio and accept full responsibility for the proper installation of the following:

_____ Installation of all materials, in accordance with manufacturer's instruction.

_____ Inspection of underlayment and replacement of any damaged or missing material.

_____ Install Roof Felt _____ 30# or _____ 15#

_____ Install drip edge.

_____ New Power Vent (Electrical Permit Required).

_____ Calculate required roof ventilation and install, as per calculations. 1/150 or 1/300 of attic area to be vented. **See Section 806.2 of the 2013 Residential Code of Ohio**, which states that the total net free ventilating area shall not be less than 1/150 of the area of the space ventilated except that reduction of the total area to 1/300 is permitted provided that a least 50 percent and not more than 80 percent of the required ventilating area is provided by ventilators located in the upper portion of the space to be ventilated at least 3 feet above the eave or cornice vents with the balance of the required ventilation provided by eave or cornice vents. As an alternative, the net free cross-ventilation area may be reduced to 1/300 when a Class I or II vapor barrier is installed on the warm-in-winter side of the ceiling.

_____ Replace step, chimney and pipe flashing, as needed.

_____ Install ice barrier, at all eaves, to extend to a point 24" inside the exterior wall line of the Building.

- Formula for determining current width of ice guard: Soffit width + wall thickness + 24"
- Example- soffit width 12" + wood frame wall with siding 5" + 24" = 41" wide ice guard
- Key- wood wall 5"
Mason wall 8"

Contractor/Installer Signature: _____ Date: _____

Note#1: If the homeowner obtains this permit on behalf of a Contractor, you are liable for all work including any violations or uncompleted work. Contractors must be currently registered.

Note #2: If a Contractor engages a Subcontractor subsequent to application for the permit and obtaining the permit, the Contractor shall be responsible to immediately notify the Building & Zoning Department as to the Subcontractor engaged, along with that company's and/or individual's license and registration number.

Ice Guard Inspection required. Please give a ½ hour notice, prior to completing ice guard installation.